

ADDENDUM No. 3
TO THE
CONTRACT DOCUMENTS
JUNE 20, 2024

PROJECT No. 9557580 SESP ROOMS 1752-1758 X-RAY REPLACEMENT PROJECT

## **GENERAL**

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated April 2024, and consists of pages AD1-1. The following changes, additions and/or deletions shall be made to the following documents; all other conditions shall remain the same.

## ITEM NO. I – CONTRACT DOCUMENTS ANNOUNCEMENT TO PREQUALIFIED BIDDERS SUPPLEMENTARY INSTRUCTIONS TO BIDDERS

1. CHANGE Bid deadline to June 26, 2024, at 2:00 p.m.

## ITEM NO. II - CLARIFICATIONS

Q1: Addendum #2 identified Armstrong Cirrus #859; please note that product does not exist. Please clarify.

A1: ACT-1

Manufacturer: Armstrong Style: Cirrus Tegular

Item: 589 Color: White Size: 24" x 24"

Profile: Beveled Tegular Profile

Suspension: 9/16"

Valz Games

DocuSigned by:

Craig Ganes – Project Manager Facilities Design & Construction

UC Davis Health