

# 9557730 - ACC 0611 RAD CT Scanner Replacement

4860 Y Street Sacramento, CA 95817



Date Thu 08/17/2023

Job #

Prepared By Faisal Alhabbal

## Weather

6:00 AM

71°

Partially cloudy

Wind: 6 MPH | Precipitation: .0" | Humidity: 68%

12:00 PM

88°

Clear

Wind: 7 MPH | Precipitation: .0" | Humidity: 43%

4:00 PM

100°

Clear

Wind: 10 MPH | Precipitation: .0" | Humidity: 31%

## Work Logs



No entry


Name	Description	Total Hours To Date
Total		16

## General Notes

### 1. MRI Trailer Photos

Faisal Alhabbal | 08/18/23 | 10:32AM






2. PO&M Photos:

Andrew

"This is what I found: The North(and South) MRI trailers are fed from the main electric room in the basement floor of the ACC building via the Normal(as opposed to Emergency) Switchgear labeled in the drawings as "USS-NA""USS-NB"

See sheets E 2.1, E 2.2".  
Faisal Alhabbal | 08/18/23 | 10:41AM



Attachments: [PDF E 2.1](#) | [PDF E 2.2](#)

I, Faisal Alhabbal, have reviewed and completed this report.

Faisal Alhabbal | 08/18/23 | 10:43AM