

## ADDENDUM NO. 4 TO THE CONTRACT DOCUMENTS NOVEMBER 21, 2025

## **GENERAL**

This addendum forms a part of the Contract Documents and modifies Addendum No. 2 dated November 10, 2025, and consists of page AD4-1. The following changes, additions and/or deletions shall be made to the following documents; all other conditions shall remain the same.

## ITEM NO. I - CONTRACT DOCUMENTS - ADDENDUM NO. 2

CHANGE: Answer to Clarification 17 on Addendum No. 2 as follows:

17. **Question:** Please inform which (if any) Emergency Power electrical panels will require energized work because they cannot be shut down.

Answer: For bidding purposes, please assume all electrical work will be performed de-energized.

DocuSigned by:

raig Ganes

Craig Ganes – Project Manager Facilities Planning & Development

UC Davis Health