

# HGA

1200 R St, Suite 100  
Sacramento, CA 95811  
(916) 787-5100 fax (916) 784-7738

---

## UC DAVIS: PSSB NETV2 UPGRADE

### Structural Calculations

OFFICE OF THE STATE FIRE MARSHAL  
APPROVED FIRE AND PANIC ONLY

*Will Gilliland*  
Will Gilliland  
Fire Inspector  
On behalf of: Stephen Guarino  
Lead Designated Campus Fire Marshal

Approval of this plan does not authorize or approve any omission or deviation from applicable regulations. Final approval is subject to field inspection. One set of approved plans shall be available on the project site at all times.



UC DAVIS HEALTH BUILDING DEPARTMENT

**APPROVED**

REVIEWED FOR CODE COMPLIANCE

The set of plans and specifications must be kept on the job site at all times and it is unlawful to make any changes or alterations to the approved set without written permission from the Building Department.

The approval of this plan and specifications SHALL NOT be held to permit or approve the violation of any University Policy or State Building Code.

BY: Paul R Menard AIA, CBO

DATE: 1/10/2024

PROJECT #: UCDH-2023-0230

UC Davis Health  
Sacramento, CA 95817

This approval includes 19 pages.

Commission No: 1500-159-01  
4150 V st, Sacramento, CA 95817  
Date: June 13, 2023  
**Resubmittal 01: October 27, 2023**

---



## Patient Support Services, 4150 V St, Sacramento, CA 95817, USA

Latitude, Longitude: 38.5561454, -121.4567732



<b>Date</b>	6/13/2023, 1:27:33 PM
<b>Design Code Reference Document</b>	ASCE7-16
<b>Risk Category</b>	IV
<b>Site Class</b>	D - Default (See Section 11.4.3)

Type	Value	Description
$S_S$	0.549	$MCE_R$ ground motion. (for 0.2 second period)
$S_1$	0.248	$MCE_R$ ground motion. (for 1.0s period)
$S_{MS}$	0.747	Site-modified spectral acceleration value
$S_{M1}$	null -See Section 11.4.8	Site-modified spectral acceleration value
$S_{DS}$	0.498	Numeric seismic design value at 0.2 second SA
$S_{D1}$	null -See Section 11.4.8	Numeric seismic design value at 1.0 second SA

Type	Value	Description
SDC	null -See Section 11.4.8	Seismic design category
$F_a$	1.36	Site amplification factor at 0.2 second
$F_v$	null -See Section 11.4.8	Site amplification factor at 1.0 second
PGA	0.231	$MCE_G$ peak ground acceleration
$F_{PGA}$	1.369	Site amplification factor at PGA
$PGA_M$	0.316	Site modified peak ground acceleration
$T_L$	12	Long-period transition period in seconds
$S_{sRT}$	0.549	Probabilistic risk-targeted ground motion. (0.2 second)
$S_{sUH}$	0.576	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration
$S_{sD}$	1.5	Factored deterministic acceleration value. (0.2 second)
$S_{1RT}$	0.248	Probabilistic risk-targeted ground motion. (1.0 second)
$S_{1UH}$	0.263	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration.
$S_{1D}$	0.6	Factored deterministic acceleration value. (1.0 second)
$PGAd$	0.5	Factored deterministic acceleration value. (Peak Ground Acceleration)
$PGA_{UH}$	0.231	Uniform-hazard (2% probability of exceedance in 50 years) Peak Ground Acceleration
$C_{RS}$	0.953	Mapped value of the risk coefficient at short periods
$C_{R1}$	0.943	Mapped value of the risk coefficient at a period of 1 s

Type	Value	Description	
$C_v$	1.066	Vertical coefficient	P2

## DISCLAIMER



While the information presented on this website is believed to be correct, SEAOC / OSHPD and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in this web application should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. SEAOC / OSHPD do not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the seismic data provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the search results of this website.

Project \_\_\_\_\_

Subject \_\_\_\_\_

Comm No. \_\_\_\_\_ Page \_\_\_\_ of \_\_\_\_

Name \_\_\_\_\_ Date \_\_\_\_\_



EXPANSION ANCHOR ALLOWABLE STRENGTHS

TABLE 1

EXPANSION ANCHORS INSTALLED IN TO THE UNDERSIDE OF STRUCTURAL SAND-LIGHTWEIGHT CONCRETE (f'c MIN=3000 PSI) OVER METAL DECK

ANCHOR DIA. (IN)	EMBED (IN)	SHEAR (LB)	TENSION (LB)
3/8	2	747	604
1/2	2 1/4	1029	610
1/2	3 1/4	1173	1086
5/8	3 1/4	1353	836
5/8	4 1/4	2477	1941

TABLE 2

EXPANSION ANCHORS INSTALLED IN TO THE TOP OF STRUCTURAL SAND-LIGHTWEIGHT CONCRETE (f'c MIN=3000 PSI) OVER METAL DECK

ANCHOR DIA. (IN)	EMBED (IN)	SHEAR (LB)	TENSION (LB)
3/8	2	806	624
1/2	2 1/4	948	660

TABLE 3

EXPANSION ANCHORS INSTALLED IN NORMAL WEIGHT CONCRETE (f'c MIN=3000 PSI)

ANCHOR DIA. (IN)	EMBED (IN)	SHEAR (LB)	TENSION (LB)
3/8	2	1020	961
1/2	2 1/4	1580	1101
1/2	3 1/4	2591	2003
5/8	3 1/4	2579	2150
5/8	4 1/4	3772	3113

SECTION TITLE:

STANDARD PARTITION WALL DETAILS

SHEET TITLE:


EXPANSION ANCHOR ALLOWABLE STRENGTHS

OPD NO.:

ST1.04



**2019 CBC & ASCE 7-16 EQUIPMENT ANCHORAGE FORCES - CU-1**



- Height, H = 53.0 in
- Height to center of gravity, z = 27.0 in
- Width, W = 13.0 in
- Overturning Dimension, ω = 13.0 in
- # of anchors in tension, #<sub>T,ω</sub> = 2
- x = 6.5 in
- x' = 6.5 in
- Length, L = 42.0 in
- Overturning Dimension, l = 24.0 in
- # of anchors in tension, #<sub>T,l</sub> = 4
- y = 21.0 in
- y' = 21.0 in
- Weight, W<sub>p</sub> = 214 lbs
- # of anchors in shear, #<sub>V</sub> = 4
- Height of component with respect to grade, z = 40 ft
- Average roof height, h = 40 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-16, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 1.0$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.3.4 & CBC Equation 16A-39

$S_{DS} = 0.498$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.00$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-14 sec 17.2.3.4.3 d

$\Omega \text{ factor} = 1.0$

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4 \cdot a_p \cdot S_{DS} \cdot W_p / (R_p / I_p) (1 + 2z/h)$

$F_p = 0.239 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 \cdot S_{DS} \cdot I_p \cdot W_p$

$F_{p,max} = 0.797 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p$

$F_{p,min} = 0.149 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7 (F_{p,govern})$

$F_{p,ASD} = 0.167 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{pv,ASD} = 0.7 (0.2 \cdot S_{DS} \cdot W_p)$

$F_{pv,ASD} = 0.070 W_p$

**DESIGN FORCES**

$F_{p,\Omega} = F_{p,ASD} \cdot W_p \cdot \Omega \text{ factor} = 36 \text{ lbs}$

$OTM = z \cdot F_{p,\Omega} = 967 \text{ lb-in}$

$F_{pv,ASD} = 15 \text{ lbs}$

$DLRM = (0.6 W_p - F_{pv,ASD}) \cdot x_{min} = 738 \text{ lb-in}$

$T = \frac{OTM - DLRM}{\omega \cdot \#_{T,\omega}} + \frac{0.3 \cdot OTM}{l \cdot \#_{T,l}}$

**T = 12 lbs**

$V = \frac{F_{p,ASD,\Omega} \cdot (2 \cdot y_{max} / L)}{\#_V}$

**V = 9 lbs**

(V is approximate when number of anchors exceeds 4)

Use (4) - 3/8"Ø Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Slab on Grade Condition, 4" min)


R1



Architecture | Engineering | Planning

Project : UC DAVIS  
 Subject: Anchorage  
 Comm No.: 1500-159-01 Page: of  
 Name: Voznenko Date: 10/12/23

**2022 CBC & ASCE 7-16 EQUIPMENT ANCHORAGE FORCES CU-1**



Height, H = 53.0 in  
 Width, W = 13.0 in  
 Overturning Dimension,  $\omega$  = 13.0 in  
 # of anchors in tension,  $\#_{T,\omega}$  = 2  
 $x$  = 6.5 in  
 $x'$  = 6.5 in  
 Length, L = 24.0 in  
 Weight,  $W_p$  = 214 lbs  
 # of anchors in shear,  $\#_V$  = 4  
 Height of component with respect to grade, z = 40 ft

R1

**Wind**

Wind design requirements for equipment are based on ASCE 7-16, Section 30.11

**RISK CATEGORY (OC)**

ASCE TABLE 1.5-1

RC = II

**BASIC WIND SPEED (3 SECOND GUST)**

ASCE Figure 26.5-1

V = 95 mph

**EXPOSURE CATEGORY (EC)**

ASCE SECTION 26.7

EC = C

**VELOCITY PRESSURE EXPOSURE COEFFICIENT**

ASCE Table 26.3.1

$k_z$  = 1.04

**TOPOGRAPHIC FACTOR**

ASCE Section 26.8.2

$k_{zt}$  = 1.0

**WIND DIRECTIONALITY FACTOR**

ASCE Table 26.6.1

$k_d$  = 0.85

**FORCE COEFFICIENT**

ASCE Section 29.4.1

$GC_r$  = 1.5

**Ground Elevation Factor**

ASCE Table 26.9-1

$Ke$  = 1.0

**VELOCITY PRESSURE**

ASCE Section 29.3.2

Note:  
 Load less than calculation shown in P8 in original calc package OK.

$$q_z = 0.00256 * K_z * K_{zt} * K_d * Ke * V^2$$

$q_z$  = 20.5 psf

**DESIGN WIND FORCE**

ASCE Section 29.5.1

$$P_{ASD} = 0.6 * (q_z * GC_r)$$

$P_{ASD}$  = 18.4 psf

**DESIGN FORCES**

$$F_{ASD} = P_{ASD} * (H * L / 144) = 163 \text{ lbs}$$

$$OTM = F_{ASD} * (H / 2) = 4318 \text{ lb-in}$$

$$DLRM = (0.6 W_p) * x_{min} = 835 \text{ lb-in}$$

$$T = \frac{OTM - DLRM}{\omega * \#_T}$$

T = 134 lbs

$$V = \frac{F_{ASD}}{\#_V}$$

V = 41 lbs

Use (4) 3/8" Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Slab on Grade Condition, 4" min)

~~$T_{ALL} = 1154 \text{ lbs}$~~   
 ~~$V_{ALL} = 513 \text{ lbs}$~~   
 Not used.

UNITY CHECK = 0.16 OK

R1



HGA

Project UC DAVISSubject AnchorageComm No. 1500-159-01

Page \_\_\_ of \_\_\_

Name Voznenko

Date \_\_\_\_\_

CONDENSATE UNIT (CU-1) ANCHORAGE

$$\text{MAX WT} = 214 \text{ lbs}$$

$$T_{\text{max}} = 191 \text{ lbs}$$

$$V_{\text{max}} = 55 \text{ lbs}$$

$$z = \sqrt{191^2 + 55^2} = 199 \text{ lbs}$$

$$\angle = \tan^{-1}(191/55) = 54^\circ$$

3/8"  $\varnothing$  x 2 1/2" lag screw

Check lag capacity

$$W = 214 \text{ lbs}$$

$$w'p = 214 \text{ lbs} \times 2 1/2" = 535 \text{ lbs}$$

$$z_1 = 140 \text{ lbs} (\phi = 0.5, 12 \text{ Ga}) = 140 \text{ lbs} \times \frac{2 1/2"}{8} \times \frac{3/8"}{3/8"} = 117 \text{ lbs}$$

$$z'_{LR} = \frac{1.6 \times (w'p)z}{(w'p)\cos^2\angle + z_1\sin^2\angle} = \frac{1.6 \times 535 \times 199}{535 \times \cos^2(54^\circ) + 117 \times \sin^2(54^\circ)} = 244.5 \text{ lbs}$$


$$z'_{LR} > z$$

$$244.5 \text{ lbs} > 199 \text{ lbs}$$

✓ GOOD

Please see P12

**2019 CBC & ASCE 7-16 EQUIPMENT ANCHORAGE FORCES - CU-2**



- Height, H = 38.0 in
- Height to center of gravity, z = 19.0 in
- Width, W = 13.0 in
- Overturning Dimension, ω = 13.0 in
- # of anchors in tension, #<sub>T,ω</sub> = 2
  - x = 6.5 in
  - x' = 6.5 in
- Length, L = 38.0 in
- Overturning Dimension, l = 24.0 in
- # of anchors in tension, #<sub>T,l</sub> = 4
  - y = 19.0 in
  - y' = 19.0 in
- Weight, W<sub>p</sub> = 153 lbs
- # of anchors in shear, #<sub>V</sub> = 4
- Height of component with respect to grade, z = 40 ft
- Average roof height, h = 40 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-16, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 1.0$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.3.4 & CBC Equation 16A-39

$S_{DS} = 0.498$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.00$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-14 sec 17.2.3.4.3 d

$\Omega \text{ factor} = 1.0$

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

$F_p = 0.4 \cdot a_p \cdot S_{DS} \cdot W_p / (R_p / I_p) \cdot (1 + 2z/h)$

$F_p = 0.239 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-2

$F_{p,max} = 1.6 \cdot S_{DS} \cdot I_p \cdot W_p$

$F_{p,max} = 0.797 W_p$

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$F_{p,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p$

$F_{p,min} = 0.149 W_p$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1

$F_{p,ASD} = 0.7(F_{p,govern})$

$F_{p,ASD} = 0.167 W_p$

ASCE Section 13.1.7 & 13.3.1

$F_{pv,ASD} = 0.7(0.2 \cdot S_{DS} \cdot W_p)$

$F_{pv,ASD} = 0.070 W_p$

**DESIGN FORCES**

$F_{p,\Omega} = F_{p,ASD} \cdot W_p \cdot \Omega \text{ factor} = 26 \text{ lbs}$

$OTM = z \cdot F_{p,\Omega} = 486 \text{ lb-in}$

$F_{pv,ASD} = 11 \text{ lbs}$

$DLRM = (0.6W_p - F_{pv,ASD}) \cdot x_{min} = 527 \text{ lb-in}$

$T = \frac{OTM - DLRM}{\omega \cdot \#_{T,\omega}} + \frac{0.3 \cdot OTM}{l \cdot \#_{T,l}}$

**T = 0 lbs**

$V = \frac{F_{p,ASD,\Omega} \cdot (2 \cdot y_{max} / L)}{\#_V}$


**V = 6 lbs**

(V is approximate when number of anchors exceeds 4)

Use (4) - 3/8"Ø Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Slab on Grade Condition, 4" min)



**2013 CBC & ASCE 7-10 EQUIPMENT ANCHORAGE FORCES - CU-2**



Height, H = 38.0 in  
 Width, W = 13.0 in  
 Overturning Dimension, ω = 13.0 in  
 # of anchors in tension, #<sub>T,ω</sub> = 2  
 x = 6.5 in  
 x' = 6.5 in  
 Length, L = 24.0 in  
 Weight, W<sub>p</sub> = 153 lbs  
 # of anchors in shear, #<sub>V</sub> = 4  
 Height of component with respect to grade, z = 40 ft

**Wind**

Wind design requirements for equipment are based on ASCE 7-10, Section 30.11

**RISK CATEGORY (OC)**

ASCE TABLE 1.5-1

RC = II

**BASIC WIND SPEED (3 SECOND GUST)**

ASCE Figure 26.5-1

V = 95 mph

**EXPOSURE CATEGORY (EC)**

ASCE SECTION 26.7

EC = C

**VELOCITY PRESSURE EXPOSURE COEFFICIENT**

ASCE Table 29.3.1

k<sub>z</sub> = 1.04

**TOPOGRAPHIC FACTOR**

ASCE Section 26.8.2

k<sub>zt</sub> = 1.0

**WIND DIRECTIONALITY FACTOR**

ASCE Table 26.6.1

k<sub>d</sub> = 0.90

**FORCE COEFFICIENT**

ASCE Section 29.5.1

GC<sub>r</sub> = 1.9

**VELOCITY PRESSURE**

ASCE Section 29.3.2

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V^2$$

q<sub>z</sub> = 21.7 psf

**DESIGN WIND FORCE**

ASCE Section 29.5.1

$$P_{ASD} = 0.6 * (q_z * GC_r)$$

P<sub>ASD</sub> = 24.7 psf

**DESIGN FORCES**

$$F_{ASD} = P_{ASD} * (H * L / 144) = 157 \text{ lbs}$$

$$OTM = F_{ASD} * (H / 2) = 2977 \text{ lb-in}$$

$$DLRM = (0.6 W_p) * x_{min} = 597 \text{ lb-in}$$

$$T = \frac{OTM - DLRM}{\omega * \#_T}$$

$$V = \frac{F_{ASD}}{\#_V}$$

**T = 92 lbs**

**V = 39 lbs**

Use (4) 3/8"Ø Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Slab on Grade Condition, 4" min)

Please see allowable strength

Govern

HGA

Project UC DAVISSubject AnchorageComm No. 1500-159-01

Page \_\_\_ of \_\_\_

Name Voznenko

Date \_\_\_\_\_

CONDENSATE UNIT (CU-2) ANCHORAGE

$$\text{MAX WT} = 153 \text{ lbs}$$

$$T_{\text{max}} = 92 \text{ lbs}$$

$$V_{\text{max}} = 39 \text{ lbs}$$

$$z = \sqrt{92^2 + 39^2} = 99.9 \text{ lbs}$$

$$L = \tan^{-1}(92/39) = 36^\circ$$

3/8"  $\varnothing$  x 2 1/2" lag screw

Check lag capacity

$$W = 153 \text{ lbs}$$

$$W'p = 153 \text{ lbs} \times 2 1/2" = 383 \text{ lbs}$$

$$z_1 = 140 \text{ lbs} \left( \phi = 0.5, 12 \text{ Ga} \right) = 140 \text{ lbs} \times \frac{2 1/2"}{8} \times \frac{3/8"}{3/8"} = 117 \text{ lbs}$$

$$z'_{LR} = \frac{1.0 \times (W'p) z}{(W'p) \cos^2 L + z_1 \sin^2 L} = \frac{1.0 \times 383 \times 99.9 \text{ lbs}}{383 \times \cos^2(36^\circ) + 117 \times \sin^2(36^\circ)} = 189.4 \text{ lbs}$$

$$z'_{LR} > z$$

$$189.4 \text{ lbs} > 99.9 \text{ lbs} \quad \checkmark \quad \underline{\underline{\text{Good}}}$$

Please see P12

**Table 12K LAG SCREWS: Reference Lateral Design Values, Z, for Single Shear (two member) Connections<sup>1,2,3,4</sup>**




for sawn lumber or SCL with ASTM A653, Grade 33 steel side plate (for  $t_s < 1/4"$ ) or ASTM A 36 steel side plate (for  $t_s = 1/4"$ )  
(tabulated lateral design values are calculated based on an assumed length of lag screw penetration, p, into the main member equal to 8D)

Side Member Thickness $t_s$ in.	Lag Screw Diameter D in.	G=0.67 Red Oak		G=0.55 Mixed Maple Southern Pine		G=0.5 Douglas Fir-Larch		G=0.48 Douglas Fir-Larch (N)		G=0.46 Douglas Fir(S) Hem-Fir(N)		G=0.43 Hem-Fir		G=0.42 Spruce-Pine-Fir		G=0.37 Redwood		G=0.36 Eastern Softwoods Spruce-Pine-Fir(S) Western Cedars Western Woods		G=0.35 Northern Species	
		$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.	$Z_{II}$ lbs.	$Z_{I}$ lbs.
0.075 (14 gage)	1/4	170	130	160	120	150	110	150	110	150	100	140	100	140	100	130	90	130	90	130	90
	5/16	220	160	200	140	190	130	190	130	190	130	180	120	180	120	170	110	170	110	160	100
	3/8	220	160	200	140	200	130	190	130	190	120	180	120	180	120	170	110	170	100	170	100
0.105 (12 gage)	1/4	180	140	170	130	160	120	160	120	160	110	150	110	150	110	140	100	140	100	140	90
	5/16	230	170	210	150	200	140	200	140	190	130	190	130	190	120	180	110	170	110	170	110
	3/8	230	160	210	140	200	140	200	130	200	130	190	120	190	120	180	110	180	110	170	110
0.120 (11 gage)	1/4	190	150	180	130	170	120	170	120	160	120	160	110	160	110	150	100	150	100	140	100
	5/16	230	170	210	150	210	140	200	140	200	140	190	130	190	130	180	120	180	120	180	110
	3/8	240	170	220	150	210	140	210	140	200	130	200	130	190	120	180	110	180	110	180	110
0.134 (10 gage)	1/4	200	150	180	140	180	130	170	130	170	120	160	120	160	110	150	110	150	100	150	100
	5/16	240	180	220	160	210	150	210	140	200	140	200	130	200	130	190	120	180	120	180	120
	3/8	240	170	220	150	220	140	210	140	210	140	200	130	200	130	190	120	190	120	180	110
0.179 (7 gage)	1/4	220	170	210	150	200	150	200	140	190	140	190	130	190	130	180	120	170	120	170	120
	5/16	260	190	240	170	230	160	230	160	230	150	220	150	220	150	210	130	200	130	200	130
	3/8	270	190	250	170	240	160	240	160	230	150	220	140	220	140	210	130	210	130	200	130
0.239 (3 gage)	1/4	240	180	220	160	210	150	210	150	200	140	190	140	190	130	180	120	180	120	180	120
	5/16	300	220	280	190	270	180	260	180	260	170	250	160	250	160	230	150	230	150	230	140
	3/8	310	220	280	190	270	180	270	180	260	170	250	160	250	160	240	140	230	140	230	140
	7/16	420	290	390	260	380	240	370	240	360	230	350	220	350	220	330	200	330	200	320	190
	1/2	510	340	470	300	460	290	450	280	440	270	430	260	420	260	400	240	400	230	390	230
	5/8	770	490	710	430	680	400	680	400	660	380	640	370	630	360	600	330	590	330	580	320
	3/4	1110	670	1020	590	980	560	970	550	950	530	920	500	910	500	860	450	850	450	840	440
	7/8	1510	880	1390	780	1330	730	1320	710	1280	690	1250	650	1230	650	1170	590	1160	590	1140	570
	1	1940	1100	1780	960	1710	910	1700	890	1650	860	1600	820	1590	810	1500	740	1480	730	1460	710
1/4	1/4	240	180	220	160	210	150	210	150	200	140	200	140	190	130	180	120	180	120	180	120
	5/16	310	220	280	200	270	180	270	180	260	170	250	170	250	160	230	150	230	150	230	140
	3/8	320	220	290	190	280	180	270	180	270	170	260	160	250	160	240	150	240	140	230	140
	7/16	480	320	440	280	420	270	420	260	410	250	390	240	390	230	370	220	360	210	360	210
	1/2	580	390	540	340	520	320	510	320	500	310	480	290	480	290	460	270	450	260	440	260
	5/8	850	530	780	470	750	440	740	440	720	420	700	400	690	400	660	370	650	360	640	350
	3/4	1200	730	1100	640	1060	600	1050	590	1020	570	990	540	980	530	930	490	920	480	900	470
	7/8	1600	930	1470	820	1410	770	1400	750	1360	720	1320	690	1310	680	1240	630	1220	620	1200	600
1	2040	1150	1870	1000	1800	950	1780	930	1730	900	1680	850	1660	840	1570	770	1550	760	1530	740	

1. Tabulated lateral design values, Z, shall be multiplied by all applicable adjustment factors (see Table 11.3.1).
2. Tabulated lateral design values, Z, are for "reduced body diameter" lag screws (see Appendix Table L2) inserted in side grain with screw axis perpendicular to wood fibers; screw penetration, p, into the main member equal to 8D; dowel bearing strengths,  $F_{\perp}$ , of 61,850 psi for ASTM A653, Grade 33 steel and 87,000 psi for ASTM A36 steel and screw bending yield strengths,  $F_{yb}$ , of 70,000 psi for  $D = 1/4"$ , 60,000 psi for  $D = 3/16"$ , and 45,000 psi for  $D = 3/8"$ .
3. Where the lag screw penetration, p, is less than 8D but not less than 4D, tabulated lateral design values, Z, shall be multiplied by p/8D or lateral design values shall be calculated using the provisions of 12.3 for the reduced penetration.
4. The length of lag screw penetration, p, not including the length of the tapered tip, E (see Appendix Table L2), of the lag screw into the main member shall not be less than 4D. See 12.1.4.6 for minimum length of penetration,  $p_{min}$ .

**2019 CBC & ASCE 7-16 EQUIPMENT ANCHORAGE FORCES - UPS**



- Height, H = 78.7 in
- Height to center of gravity, z = 35.6 in
- Width, W = 39.1 in
- Overturning Dimension,  $\omega$  = 39.1 in
- # of anchors in tension,  $\#_{T,\omega}$  = 2
- x = 19.6 in
- x' = 19.6 in
- Length, L = 47.4 in
- Overturning Dimension,  $l$  = 47.4 in
- # of anchors in tension,  $\#_{T,l}$  = 4
- y = 23.7 in
- y' = 23.7 in
- Weight,  $W_p$  = 842 lbs
- # of anchors in shear,  $\#_V$  = 4
- Height of component with respect to grade, z = 0 ft
- Average roof height, h = 1 ft

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-16, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$a_p = 2.5$

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

$R_p = 2.5$

**DESIGN SPECTRAL RESPONSE ACCELERATION**

CBC Section 1613A.3.4 & CBC Equation 16A-39

$S_{DS} = 0.498$

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

$I_p = 1.00$

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Section 13.4.2.1 and ACI 318-14 sec 17.2.3.4.3 d

$\Omega$  factor = 2.0

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1  
 ASCE Section 13.3.1 & ASCE Equation 13.3-2  
 ASCE Section 13.3.1 & ASCE Equation 13.3-3

$$F_p = 0.4 \cdot a_p \cdot S_{DS} \cdot W_p / (R_p / I_p) \cdot (1 + 2z/h)$$

$$F_{p,max} = 1.6 \cdot S_{DS} \cdot I_p \cdot W_p$$

$$F_{p,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p$$

$$F_p = 0.199 W_p$$

$$F_{p,max} = 0.797 W_p$$

$$F_{p,min} = 0.149 W_p$$

**SEISMIC DESIGN FORCES (ASD)**

ASCE Section 13.1.7 & 13.3.1  
 ASCE Section 13.1.7 & 13.3.1

$$F_{p,ASD} = 0.7 (F_{p,govern})$$

$$F_{pv,ASD} = 0.7 (0.2 \cdot S_{DS} \cdot W_p)$$

$$F_{p,ASD} = 0.139 W_p$$

$$F_{pv,ASD} = 0.070 W_p$$

**DESIGN FORCES**

$$F_{p,\Omega} = F_{p,ASD} \cdot W_p \cdot \Omega \text{ factor} = 235 \text{ lbs}$$

$$OTM = z \cdot F_{p,\Omega} = 8359 \text{ lb-in}$$

$$F_{pv,ASD} = 59 \text{ lbs}$$

$$DLRM = (0.6 W_p - F_{pv,ASD}) \cdot x_{min} = 8751 \text{ lb-in}$$

$$T = \frac{OTM - DLRM}{\omega \cdot \#_{T,\omega}} + \frac{0.3 \cdot OTM}{l \cdot \#_{T,l}}$$

**T = 8 lbs**

$$V = \frac{F_{p,ASD,\Omega} \cdot (2 \cdot y_{max} / L)}{\#_V}$$

**V = 59 lbs**

(V is approximate when number of anchors exceeds 4)

**Use (4) - 3/8"Ø Hilti Kwik Bolt TZ w/ 2" Effective Embedment (Slab on Grade Condition, 4" min)**

$$T_{ALL} = 961 \text{ lbs}$$

$$V_{ALL} = 1020 \text{ lbs}$$

UNITY CHECK = 0.07 **OK**




R1

# HGA

Project : UC DAVIS  
 Subject: Anchorage  
 Comm No.: 1500-159-01 Page: of  
 Name: Voznenko Date: 10/12/23

**2022 CBC & ASCE 7-16 EQUIPMENT ANCHORAGE FORCES (LRFD) - CFCI**



R1

Height, H = 84.0 in  
 Height to center of gravity, z = 42.0 in  
 Width, W = 20.0 in  
 Overturning Dimension, ω = 16.0 in  
 # of anchors in tension, #<sub>T,ω</sub> = 2  
 x = 10.0 in  
 x' = 8.0 in  
 Length, L = 24.8 in  
 Overturning Dimension, l = 24.8 in  
 # of anchors in tension, #<sub>T,l</sub> = 2  
 y = 12.4 in  
 y' = 12.4 in  
 Weight, W<sub>p</sub> = 750 lbs  
 # of anchors in shear, #<sub>V</sub> = 4  
 Height of component with respect to grade, z = 0.00 ft  
 Average roof height, h = 1.00 ft

R1

**Seismic**

Seismic design requirements for equipment are based on ASCE 7-16, Chapter 13.

**COMPONENT AMPLIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

a<sub>p</sub> = 2.5

**COMPONENT RESPONSE MODIFICATION FACTOR**

ASCE Section 13.5, 13.6 & ASCE Table 13.5-1, 13.6-1

R<sub>p</sub> = 2.5

**DESIGN SPECTRAL RESPONSE ACCELERATION**

S<sub>DS</sub> = 0.498

**COMPONENT IMPORTANCE FACTOR**

ASCE Section 13.1.3

I<sub>p</sub> = 1.50

**ATTACHMENT FACTOR IN CONCRETE OR MASONRY**

ASCE Tables 13.5-1, 13.6-1

Ω factor = 2.0

**SEISMIC DESIGN FORCE**

ASCE Section 13.3.1 & ASCE Equation 13.3-1

ASCE Section 13.3.1 & ASCE Equation 13.3-2

ASCE Section 13.3.1 & ASCE Equation 13.3-3

$$F_p = 0.4 \cdot a_p \cdot S_{DS} \cdot W_p / (R_p / I_p) \cdot (1 + 2z/h)$$

$$F_{p,max} = 1.6 \cdot S_{DS} \cdot I_p \cdot W_p$$

$$F_{p,min} = 0.3 \cdot S_{DS} \cdot I_p \cdot W_p$$

$$F_p = 0.299 W_p$$

$$F_{p,max} = 1.195 W_p$$

$$F_{p,min} = 0.224 W_p$$

**SEISMIC DESIGN FORCES**

ASCE Section 13.1.8 & 13.3.1

ASCE Section 13.1.8 & 13.3.1

$$F_{p,v} = F_{p,govern}$$

$$F_{p,v} = 0.2 \cdot S_{DS} \cdot W_p$$

$$F_p = 0.299 W_p$$

$$F_{p,v} = 0.100 W_p$$

**DESIGN FORCES**

$$F_{p,\Omega} = F_p \cdot W_p \cdot \Omega \text{ factor} = 448 \text{ lbs}$$

$$OTM = z \cdot F_{p,\Omega} = 18824 \text{ lb-in}$$

$$F_{p,v} = 75 \text{ lbs}$$

$$DLRM = (0.9W_p - F_{p,v}) \cdot x_{min} = 4802 \text{ lb-in}$$

$$T = \frac{OTM - DLRM}{\omega \cdot \#_{T,\omega}} + \frac{0.3 \cdot OTM}{l \cdot \#_{T,l}}$$

T = 552 lbs

$$V = \frac{F_{p,\Omega} \cdot (2 \cdot y_{max} / L)}{\#_V}$$

V = 112 lbs

(V is approximate when number of anchors exceeds 4)


Use (4) - 1/2"Ø Hilti Kwik Bolt T22 w/ 2" Effective Embedment (Slab on Grade Condition, 4" min)

T<sub>ALL</sub> = 1586 lbs

see HILTI PROFIS

V<sub>ALL</sub> = 2249 lbs

UNITY CHECK = 0.40 OK



$$Sds = 0.498$$

$$Ap = 1.0$$

$$Rp = 2.5$$

$$Ip = 1.0$$

$$Wt = 46 \text{ lbs} = Fpv$$

$$Fpv = 0.2 \times Sds \times Ip \times Wp = 0.2 \times 0.498 \times 1.0 \times 46 \text{ lbs} = 4.6 \text{ lbs}$$

$$Fp = \frac{0.4 \times Ap \times Sds}{Rp / Ip} (1 + 2 z/h) =$$

$$= \frac{0.4 \times 1.0 \times 0.498}{2.5 / 1.0} (1 + 2) = 0.24 Wp = 0.24 \times 46 \text{ lbs} = 11 \text{ lbs}$$

$$Fp_{min} = 0.3 Sds \times Ip \times Wp = 0.3 \times 0.498 \times 1.0 \times 46 = 6.9 \text{ lbs}$$

$$Fp = 11 \text{ lbs}$$

Shear allowable strength check

$$V = (Wt + 0.7 Fpv) / \# \text{ screw} (4) = (46 \text{ lbs} + 0.7 \times 4.6 \text{ lbs}) / 4 = 12.3 \text{ lbs}$$

$$V/V_{all} = 12.3 \text{ lbs} / 69 \text{ lbs} = 0.18$$

Tension allowable strength check

$$T = \frac{(Wt + 0.7 Fpv) \times 6.75 + 0.7 Fp \times 2.5}{(14 - 4) \times 2 \text{ screw}} = \frac{(46 \text{ lbs} + 0.7 \times 4.6 \text{ lbs}) \times 6.75 + 0.7 \times 11 \text{ lbs} \times 2.5}{20} = 17.6$$

T/Tall

$$17.6 / 109 \text{ lbs} = 0.16$$

$$V/V_{all} + T/T_{all} \leq 1.0$$

$$0.18 + 0.16$$

$$0.34 \leq 1.0 \quad \underline{\underline{\text{GOOD}}}$$

please see next pages for allowable strength

c) The metal-critical joint may fail in one of two ways. Failure occurs when the resistance of the screw head to embedment is greater than the resistance of the metal to lateral and/or withdrawal load, and the screw tears away from the metal framing. Failure also occurs when thin metal in a metal-to-plywood joint crushes or tears away from the screw.

Tables 1 and 2 present ultimate lateral loads for wood- and sheet-metal-screw connections in plywood-and-metal joints. Loaded end distance in these tests was one inch. Plywood face grain was parallel to the load since this direction yields the lowest lateral loads when the joint is plywood-critical. All wood-screw specimens were tested with a 3/16-in.-thick steel side plate, and values should be modified if thinner steel is used.

TABLE 1

SCREWS: METAL-TO-PLYWOOD CONNECTIONS<sup>(a)</sup>

Depth of Threaded Penetration (in.)	Ultimate Lateral Load (lbf) <sup>(b)</sup>					
	Wood Screws			Sheet Metal Screws		
	#8	#10	#12	#8	#10	#12
1/2	415	(500)	590	465	(565)	670
5/8	-	-	-	500	(600)	705
3/4	-	-	-	590	(655)	715

(a) Plywood was C-D grade with exterior glue (all plies Group 1), face grain parallel to load. Side plate was 3/16"-thick steel.

(b) Values in parentheses are estimates based on other tests.





TABLE 2

SHEET METAL SCREWS: PLYWOOD-TO-METAL CONNECTIONS<sup>(a)</sup>

Framing	Plywood Thickness (in.)	Ultimate Lateral Load (lbf) <sup>(b)</sup>				
		Screw Size				1/4"-20 Self Tapping Screw
		#8	#10	#12	#14	
0.080-in. Aluminum	1/4	330	360	390	410	590
	1/2	630	850*	860	920	970
	3/4	910*	930*	1250	1330	1440
0.078-in. Galvanized Steel (14 gage)	1/4	360	380	400	410	650
	1/2	700*	890*	900	920	970
	3/4	700*	950*	1300*	1390*	1500

(a) Plywood was A-C EXT (all plies Group 1), face grain parallel to load.

(b) Loads denoted by an asterisk(\*) were limited by screw-to-framing strength; others were limited by plywood strength.



**Withdrawal:**

Tables 3 and 4 present average ultimate withdrawal loads for wood and sheet metal screws in plywood-and-metal joints, based on analysis of test results. Wood screws have a tapered shank and are threaded for only 2/3 of their length. Sheet metal screws typically have higher ultimate load than wood screws in the smaller gages, because of their uniform shank diameter and full-length thread. The difference is not as apparent in the larger gages and lengths because the taper is not as significant.

Values shown in Table 3 for wood screws are based on 1/4-in. protrusion of the wood screw from the back of the panel. This was to assure measurable length of thread embedment in the wood, since the tip of the tapered wood screw may be smaller than the pilot hole. This was not a factor for sheet metal screws due to their uniform shanks.

TABLE 3

**WOOD AND SHEET METAL SCREWS: METAL-TO-PLYWOOD CONNECTIONS<sup>(a)</sup>**

Depth of Threaded Penetration (in.)	Average Ultimate Withdrawal Load (lbf)					
	Screw Size					
	#6	#8	#10	#12	#14	#16
3/8	150	180	205	-	-	-
1/2	200	240	275	315	350	-
5/8	250	295	345	390	440	-
3/4	300	355	415	470	525	-
1	-	-	-	625	700	775
1-1/8	-	-	-	705	790	875
2-1/4	-	-	-	-	1580	-

(a) Plywood was C-D grade with exterior glue (all plies Group 1).





TABLE 4

**SHEET METAL SCREWS: PLYWOOD-TO-METAL CONNECTIONS<sup>(a)</sup>**

Framing	Plywood Thickness (in.)	Ultimate Withdrawal Load (lbf) <sup>(b)</sup>				
		Screw Size				1/4"-20 Self Tapping Screw
		#8	#10	#12	#14	
0.080-in. Aluminum	1/4	130	150	170	180	220
	1/2	350	470	500	520	500
0.078-in. Galvanized Steel (14 gage)	3/4	660	680	790	850*	790*
	1/4	130	150	170	180	220
Galvanized Steel (14 gage)	1/2	350	470	500	520	500
	3/4	660	680	800	900	850

(a) Plywood was A-C EXT (all plies Group 1).

(b) Loads denoted by an asterisk(\*) were limited by screw-to-framing strength; others were limited by plywood strength.





### Adjustment for Species Other Than Group 1:

All the ultimate loads presented in Tables 1 through 4 are based on plywood panels of all-Group 1 construction. For plywood panels of other species groups, the ultimate loads in these tables must be adjusted by correction factors presented in Table 5. Correction factors apply for both lateral and withdrawal loading. The adjustment factor for the highest numbered species group present in any veneer should be used.

### Fastening Into Plywood Panel Edges

Fastening into plywood panel edges is not normally recommended. For some purposes, however, edge fastening may be necessary. Table 6 presents ultimate lateral and withdrawal loads for various sizes of wood screws in this application.

TABLE 5

**LOAD ADJUSTMENT FOR SCREWS INTO PLYWOOD FOR SPECIES GROUPS NOTED<sup>(a)</sup>(b)**

Types of Loading	All-Group 1	All-Group 2	All-Group 3, 4, 5
Lateral	100%	78%	78%
Withdrawal	100%	60%	47%

(a) Adjustments based on the species groups for plywood shown in Voluntary Product Standard PS 1 and the equations in U.S. Agricultural Handbook No. 72.

(b) Face, back, and core veneer must be of the same species group. When species group is unknown, assume all-Group 4.


TABLE 6

**WOOD SCREWS: PLYWOOD-TO-PLYWOOD EDGE CONNECTIONS<sup>(a)</sup>**

Depth of Threaded Penetration (in.)	Ultimate Lateral Load (lbf) <sup>(b)</sup>			Ultimate Withdrawal Load (lbf) <sup>(b)</sup>		
	#8	#10	#12	#8	#10	#12
1	180	(185)	195	360	(405)	450
1-1/2	180	(185)	195	410	(455)	500

(a) Plywood receiving screw thread was 3/4"-thick C-D grade with exterior glue (Group 2 inner plies).

(b) Values in parentheses are estimates based on other tests.



## ESTIMATING ALLOWABLE DESIGN LOADS

It is the responsibility of the designer to select a working load suitable for the particular application. A high degree of variability is inherent in individual fastener test results. Therefore, for screws in withdrawal, a working load of about one-sixth of the ultimate load has traditionally been used for long-duration loads. For normal load duration, the long-term working load may be increased by 10 percent. Normal load duration contemplates fully stressing the connection for approximately ten years, either continuously or cumulatively.

For laterally loaded screws, a working load of normal duration may be approximated by dividing the tabulated ultimate load by 5 or 6. For practically all laterally loaded screw connections shown, the normal-duration working load will correspond to a joint slip of less than 0.01 inch.

Adjustments for shorter or longer duration of load apply to design values for mechanical fasteners where the strength of the wood (i.e., not the strength of the metal fastener) determines the load capacity. Adjustments of design values for varying durations of load and combinations of load should be in accordance with the current AF&PA *National Design Specification for Wood Construction*.